

NOTICE OF TEST RESULTS

Facility: Gentry Residential Treatment Center

Test Date: February 10, 2026

Date Results Received: March 18, 2026

Summary of Results:

- Type of Result: FINAL
- Number of Outlets Tested: 33
- Number of Outlets with results at or above 5ppb: 2
 - See enclosed email from vendor

Implemented Remediation Efforts:

- Established disuse of above listed outlets and posted signage.
 - Install filtration system from Walter Louis Fluid Technologies and post non potable water sign above fixture.

OA-FMDC Next Steps:

- All fixtures above 5PPB will be retested once remediation is complete

Requirements of Statute:

- DYS must make all test results and any lead remediation plans available on the school's website within two weeks of receiving said test result. R.S.Mo. § 160.077.4(3)
- If a test result exceeds 5ppb, DYS shall contact parents and staff via written notification within seven business days of the above date. This notice must include:
 - The above written test results and explanation;
 - A description of the previously implemented and planned remediation efforts; and
 - A description of general health effects of lead contamination and community specific resources. *Id.* at (7).
- OA-FMDC shall provide bottled water if the disuse of outlets during the remediation and retesting period results in not enough water to meet the drinking water needs of the students, teachers, and staff. *Id.*
- DYS shall submit annual testing results to DHSS. *Id.*

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
46	Gentry Res Treatment Center - Cabool, MO	2001 DYS Drive Cabool, MO 65689	SO# 54425	
1	SAMPLE LOCATION	1 FD Nurse's Office Faucet	ND	ND
2	SAMPLE LOCATION	1 FL Nurse's Office Faucet	ND	ND
3	SAMPLE LOCATION	2 FD Lobby Restroom Faucet	ND	ND
4	SAMPLE LOCATION	2 FL Lobby Restroom Faucet	ND	ND
5	SAMPLE LOCATION	3 FD Lobby Bottle Filler	ND	ND
6	SAMPLE LOCATION	3 FL Lobby Bottle Filler	ND	ND
7	SAMPLE LOCATION	4 FD Odessey Classroom Bath Faucet	ND	ND
8	SAMPLE LOCATION	4 FL Odessey Classroom Bath Faucet	ND	ND
9	SAMPLE LOCATION	5 FD Odessey Dormatory Faucet	ND	ND
10	SAMPLE LOCATION	5 FL Odessey Dormatory Faucet	ND	ND
11	SAMPLE LOCATION	6 FD Odyssey Dorm Restroom Faucet	ND	ND
12	SAMPLE LOCATION	6 FL Odyssey Dorm Restroom Faucet	ND	ND
13	SAMPLE LOCATION	7 FD Odyssey Dorm Restroom Faucet	ND	ND
14	SAMPLE LOCATION	7 FL Odyssey Dorm Restroom Faucet	ND	ND
15	SAMPLE LOCATION	8 FD Odyssey Dorm Restroom Faucet	ND	ND
16	SAMPLE LOCATION	8 FL Odyssey Dorm Restroom Faucet	ND	ND
17	SAMPLE LOCATION	9 FD Odyssey Laundry Faucet	0.004 mg/L	4 ppb
18	SAMPLE LOCATION	9 FL Odyssey Laundry Faucet	ND	ND
19	SAMPLE LOCATION	10 FD Kitchen Ice Machine	ND	ND
20	SAMPLE LOCATION	10 FL Kitchen Ice Machine	ND	ND
21	SAMPLE LOCATION	11 FD Kitchen Dishwasher	ND	ND
22	SAMPLE LOCATION	11 FL Kitchen Dishwasher	ND	ND

FD = First Draw **FL** = Flush

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
46	Gentry Res Treatment Center - Cabool, MO	2001 DYS Drive Cabool, MO 65689	SO# 54425	
23	SAMPLE LOCATION	12 FD Kitchen Faucet	0.001 mg/L	1 ppb
24	SAMPLE LOCATION	12 FL Kitchen Faucet	ND	ND
25	SAMPLE LOCATION	13 FD Kitchen Faucet	0.002 mg/L	2 ppb
26	SAMPLE LOCATION	13 FL Kitchen Faucet	ND	ND
27	SAMPLE LOCATION	14 FD Kitchen Faucet	ND	ND
28	SAMPLE LOCATION	14 FL Kitchen Faucet	ND	ND
29	SAMPLE LOCATION	15 FD Kitchen Faucet	0.003 mg/L	3 ppb
30	SAMPLE LOCATION	15 FL Kitchen Faucet	ND	ND
31	SAMPLE LOCATION	16 FD Millenium Dorm Laundry Faucet	ND	ND
32	SAMPLE LOCATION	16 FL Millenium Dorm Laundry Faucet	ND	ND
33	SAMPLE LOCATION	17 FD Millenium Dorm Restroom Faucet	ND	ND
34	SAMPLE LOCATION	17 FL Millenium Dorm Restroom Faucet	ND	ND
35	SAMPLE LOCATION	18 FD Millenium Dorm Restroom Faucet	ND	ND
36	SAMPLE LOCATION	18 FL Millenium Dorm Restroom Faucet	ND	ND
37	SAMPLE LOCATION	19 FD Millenium Dorm Restroom Faucet	ND	ND
38	SAMPLE LOCATION	19 FL Millenium Dorm Restroom Faucet	ND	ND
39	SAMPLE LOCATION	20 FD Millenium Dormatory Faucet	ND	ND
40	SAMPLE LOCATION	20 FL Millenium Dormatory Faucet	ND	ND
41	SAMPLE LOCATION	21 FD Millenium Classroom Bath Faucet	ND	ND
42	SAMPLE LOCATION	21 FL Millenium Classroom Bath Faucet	ND	ND
43	SAMPLE LOCATION	22 FD Kitchen Water Machine Dining Area	ND	ND
44	SAMPLE LOCATION	22 FL Kitchen Water Machine Dining Area	ND	ND

FD = First Draw **FL = Flush**

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
46	Gentry Res Treatment Center - Cabool, MO	2001 DYS Drive Cabool, MO 65689	SO# 54425	
45	SAMPLE LOCATION	23 FD Source	0.007 mg/L	7 ppb
46	SAMPLE LOCATION	23 FL Source	0.006 mg/L	6 ppb

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491814

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #1FD 4191535(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:48		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491815

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #1FL 4191568(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:50		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491816****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #2FD 4191539(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:45		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491817

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #2FL 4191569(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:47		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491818

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #3FD 4191547(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:42		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491819

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #3FL 4191562(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:44		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491820****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #4FD 4191543(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:52		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491821****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #4FL 4191554(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:54		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491822****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #5FD 4191532(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:53		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491823

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #5FL 4191555(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:55		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491824****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #6FD 4191537(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:58		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491825****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #6FL 4191560(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:00		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491826

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #7FD 4191529(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:01		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491827

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #7FL 4191563(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:03		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491828****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #8FD 4191530(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:03		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491829

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #8FL 4191549(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:05		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491830

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #9FD 4191531(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.004	1	2/10/2026 06:50		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491831

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #9FL 4191548(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:52		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491832

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #10FD 4191542(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:13		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491833

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #10FL 4191566(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:15		2/23/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491834****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #11FD 4191544(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:25		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491835

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #11FL 4191559(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:27		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491836****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #12FD 4191546(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	2/10/2026 07:29		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491837

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #12FL 4191557(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:31		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491838

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #13FD 4191528(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	2/10/2026 07:31		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491839

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #13FL 4191553(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:33		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491840

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #14FD 4191527(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:18		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491841

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #14FL 4191567(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:20		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491842****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #15FD 4191541(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.003	1	2/10/2026 07:21		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491843

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #15FL 4191558(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:23		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491844****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #16FD 4191536(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:44		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491845

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #16FL 4191564(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:46		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491846****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #17FD 4191533(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:38		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491847

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #17FL 4191552(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:40		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491848

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #18FD 4191540(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:34		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491849****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #18FL 4191551(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:36		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491850****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #19FD 4191525(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:30		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491851****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #19FL 4191561(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:32		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491852****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #20FD 4191534(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:41		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491853

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #20FL 4191550(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 06:43		3/4/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491854****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #21FD 4191545(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:58		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491855

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #21FL 4191565(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 08:00		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491856****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #22FD 4191538(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:36		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd556 South Mansfield, Ypsilanti, MI, 48197-5166
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491857****3/12/2026****Customer:** Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy, IL 62301-4808**Source:** #22FL 4191556(SO#-54425-GENRES)
Source City: Cabool
Source State: MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/10/2026 07:38		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491858

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #23FD 4191820(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.007	1	2/10/2026 08:06		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 491859

3/12/2026

Customer: Walter Louis Fluid Technologies
 Jenn Tapuaiga
 530 South 5th Street
 ATTN: Jenn Tapuaiga
 Quincy, IL 62301-4808

Source: #23FL 4191800(SO#-54425-GENRES)
Source City: Cabool
Source State: MO

Date/Time Received: 2/17/2026 09:35

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.006	1	2/10/2026 08:08		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.