

# Report recieved by DSS on February 9, 2026

## NOTICE OF TEST RESULTS

Facility: Northwest Regional Youth Center

Test Date: January 7, 2026

Date Results Received: February 4, 2026

### Summary of Results:

- Type of Result: Final
- Number of Outlets Tested: 27
- Number of Outlets with results at or above 5ppb: 5
  - Mechanical Room Water Main
  - Kitchen Ice Machine
  - Kitchenette Sink Faucet
  - White House Women's Restroom Faucet
  - White House Basement Bathroom Faucet

### Implemented Remediation Efforts:

- Established disuse of above listed outlets and posted signage.
  - Install filtration system from Walter Louis Fluid Technologies and post non potable water sign above fixture.

### OA-FMDC Next Steps:

- All fixtures above 5PPB will be retested once remediation is complete

### Requirements of Statute:

- DYS must make all test results and any lead remediation plans available on the school's website within two weeks of receiving said test result. R.S.Mo. § 160.077.4(3)
- If a test result exceeds 5ppb, DYS shall contact parents and staff via written notification within seven business days of the above date. This notice must include:
  - The above written test results and explanation;
  - A description of the previously implemented and planned remediation efforts; and
  - A description of general health effects of lead contamination and community specific resources. *Id.* at (7).
- OA-FMDC shall provide bottled water if the disuse of outlets during the remediation and retesting period results in not enough water to meet the drinking water needs of the students, teachers, and staff. *Id.*
- DYS shall submit annual testing results to DHSS. *Id.*

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
54	Northwest Regional Youth Center - Kansas City, MO	4901 NE Barry Road Kansas City, MO 64156	SO# 54356	
1	SAMPLE LOCATION	1 FD Mechanical Room Water Main	0.490 mg/L	490 ppb
2	SAMPLE LOCATION	1 FL Mechanical Room Water Main	0.003 mg/L	3 ppb
3	SAMPLE LOCATION	2 FD Kitchen Sprayer for Dish Prewash	ND	ND
4	SAMPLE LOCATION	2 FL Kitchen Sprayer for Dish Prewash	ND	ND
5	SAMPLE LOCATION	3 FD Kitchen Dish Machine	ND	ND
6	SAMPLE LOCATION	3 FL Kitchen Dish Machine	ND	ND
7	SAMPLE LOCATION	4 FD Kitchen Faucet #1 for Double Sink	ND	ND
8	SAMPLE LOCATION	4 FL Kitchen Faucet #1 for Double Sink	ND	ND
9	SAMPLE LOCATION	5 FD Kitchen Faucet #2 for Double Sink	0.001 mg/L	1 ppb
10	SAMPLE LOCATION	5 FL Kitchen Faucet #2 for Double Sink	ND	ND
11	SAMPLE LOCATION	6 FD Kitchen Faucet for Hand Washing	ND	ND
12	SAMPLE LOCATION	6 FL Kitchen Faucet for Hand Washing	ND	ND
13	SAMPLE LOCATION	7 FD Kitchen Ice Machine	0.009 mg/L	9 ppb
14	SAMPLE LOCATION	7 FL Kitchen Ice Machine	0.001 mg/L	1 ppb
15	SAMPLE LOCATION	8 FD Staff Restroom Faucet	ND	ND
16	SAMPLE LOCATION	8 FL Staff Restroom Faucet	ND	ND
17	SAMPLE LOCATION	9 FD Women's Restroom Faucet	ND	ND
18	SAMPLE LOCATION	9 FL Women's Restroom Faucet	ND	ND
19	SAMPLE LOCATION	10 FD Water Fountain	ND	ND
20	SAMPLE LOCATION	10 FL Water Fountain	ND	ND
21	SAMPLE LOCATION	11 FD Men's Restroom Faucet	ND	ND
22	SAMPLE LOCATION	11 FL Men's Restroom Faucet	ND	ND
23	SAMPLE LOCATION	12 FD Boy's Restroom Faucet	ND	ND
24	SAMPLE LOCATION	12 FL Boy's Restroom Faucet	ND	ND

\*\*ADVANCED  
NOTICE WRONG -  
SAID 0.049 mg/L  
(49 ppb)

**FD = First Draw**      **FL = Flush**

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
<b>54</b>	<b>Northwest Regional Youth Center - Kansas City, MO</b>	4901 NE Barry Road Kansas City, MO 64156	SO# 54356	
25	SAMPLE LOCATION	13 <b>FD</b> Boy's Restroom Faucet	ND	ND
26	SAMPLE LOCATION	13 <b>FL</b> Boy's Restroom Faucet	ND	ND
27	SAMPLE LOCATION	14 <b>FD</b> Boy's Restroom Faucet	ND	ND
28	SAMPLE LOCATION	14 <b>FL</b> Boy's Restroom Faucet	ND	ND
29	SAMPLE LOCATION	15 <b>FD</b> Water Fountain Corridor	ND	ND
30	SAMPLE LOCATION	15 <b>FL</b> Water Fountain Corridor	ND	ND
31	SAMPLE LOCATION	16 <b>FD</b> C Dorm Faucet	ND	ND
32	SAMPLE LOCATION	16 <b>FL</b> C Dorm Faucet	ND	ND
33	SAMPLE LOCATION	17 <b>FD</b> C Dorm Faucet	ND	ND
34	SAMPLE LOCATION	17 <b>FL</b> C Dorm Faucet	ND	ND
35	SAMPLE LOCATION	18 <b>FD</b> C Dorm Faucet	ND	ND
36	SAMPLE LOCATION	18 <b>FL</b> C Dorm Faucet	ND	ND
37	SAMPLE LOCATION	19 <b>FD</b> C Dorm Faucet	ND	ND
38	SAMPLE LOCATION	19 <b>FL</b> C Dorm Faucet	ND	ND
39	SAMPLE LOCATION	20 <b>FD</b> Kitchenette Sink Faucet	0.038 mg/L	38 ppb
40	SAMPLE LOCATION	20 <b>FL</b> Kitchenette Sink Faucet	ND	ND
41	SAMPLE LOCATION	21 <b>FD</b> B Dorm Water Fountain	ND	ND
42	SAMPLE LOCATION	21 <b>FL</b> B Dorm Water Fountain	ND	ND
43	SAMPLE LOCATION	22 <b>FD</b> B Dorm Restroom Faucet	ND	ND
44	SAMPLE LOCATION	22 <b>FL</b> B Dorm Restroom Faucet	ND	ND
45	SAMPLE LOCATION	23 <b>FD</b> B Dorm Restroom Faucet	ND	ND
46	SAMPLE LOCATION	23 <b>FL</b> B Dorm Restroom Faucet	ND	ND
47	SAMPLE LOCATION	24 <b>FD</b> B Dorm Restroom Faucet	ND	ND
48	SAMPLE LOCATION	24 <b>FL</b> B Dorm Restroom Faucet	ND	ND

**FD = First Draw**      **FL = Flush**

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
54	Northwest Regional Youth Center - Kansas City, MO	4901 NE Barry Road Kansas City, MO 64156	SO# 54356	
49	SAMPLE LOCATION	25 FD White House Men's Restroom Faucet	ND	ND
50	SAMPLE LOCATION	25 FL White House Men's Restroom Faucet	ND	ND
51	SAMPLE LOCATION	27 FD White House Women's Restroom Faucet	0.005 mg/L	5 ppb
52	SAMPLE LOCATION	27 FL White House Women's Restroom Faucet	ND	ND
53	SAMPLE LOCATION	28 FD White House Basement Bathroom Faucet	0.016 mg/L	28 ppb
54	SAMPLE LOCATION	28 FL White House Basement Bathroom Faucet	ND	ND

**\*\*NO  
ADVANCED  
NOTICE**

**FD = First Draw      FL = Flush**

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490288****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #1FD 4190853(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.490*	1	1/7/2026 08:09	1/19/2026	1/20/2026

Analyst	Tests
JD	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490289**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #1FL 4190892(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.003	1	1/7/2026 08:11		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490290**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #2FD 4190836(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:03		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490291**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #2FL 4190895(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:05		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490292****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #3FD 4190843(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

This 200.8 sample was run at a dilution factor of 2x, which did not affect the report limit.

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	RN	1	1/7/2026 07:33	1/19/2026 1/20/2026

Qualifiers:

RN: Please see Report Notes for qualifier detail.

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490293**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #3FL 4190887(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

This sample was diluted due to matrix interference, which triggered a raised report level.

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.010	ND	RN 10	1/7/2026 07:35	1/19/2026	1/20/2026

Qualifiers:

RN: Please see Report Notes for qualifier detail.

Analyst	Tests
JD	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490294****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #4FD 4190863(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:42		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490295****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #4FL 4190877(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:44		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490296****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #5FD 4190840(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	1/7/2026 07:45		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490297**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #5FL 4190888(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:47		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490298****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #6FD 4190839(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:50		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490299**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #6FL 4190881(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:52		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490300****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #7FD 4190842(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.009	1	1/7/2026 08:03	1/19/2026	1/20/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490301****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #7FL 4190883(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	1/7/2026 08:05		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490302****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #8FD 4190857(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:38		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490303****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #8FL 4190870(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:40		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490304**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #9FD 4190847(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:27		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490305**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #9FL 4190879(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:29		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490306****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #10FD 4190841(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:23		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490307****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #10FL 4190871(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:25		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490308****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #11FD 4190838(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:18		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490309****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #11FL 4190889(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:20		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490310**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #12FD 4190846(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:07		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490311****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #12FL 4190875(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:09		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490312****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #13FD 4190837(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:11		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490313****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #13FL 4190885(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**


Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:13		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490314****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #14FD 4190849(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:13		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490315****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #14FL 4190884(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:15		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490316****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #15FD 4190859(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:01		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490317****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #15FL 4190878(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 07:03		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490318****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #16FD 4190864(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:37		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490319**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #16FL 4190866(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:39		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490320****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #17FD 4190833(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:41		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490321****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #17FL 4190882(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:43		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490322****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #18FD 4190858(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/17/2026 06:46		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490323****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #18FL 4190869(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:48		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490324****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #19FD 4190856(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:50		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490325****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #19FL 4190876(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:52		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490326**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #20FD 4190860(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.038*	1	1/7/2026 06:54	1/19/2026	1/20/2026

Analyst	Tests
JD	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490327**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #20FL 4190872(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:56		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490328****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #21FD 4190854(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.005	ND	5	1/7/2026 06:22		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490329****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #21FL 4190865(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:24		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490330****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #22FD 4190834(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:12		1/18/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490331****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #22FL 4190894(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:14		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490332****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #23FD 4190862(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:15		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490333****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #23FL 4190890(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:17		1/18/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490334****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #24FD 4190848(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:18		1/20/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490335****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #24FL 4190867(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 06:20		1/20/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490336****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #25FD 4190844(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 08:21		1/20/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490337**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy , IL 62301-4808

**Source:** #25FL 4190873(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 08:23		1/20/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490338****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #27FD 4190855(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.005	1	1/7/2026 08:26		1/20/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490339**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #27FL 4190891(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 08:28		1/20/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 490340**

**1/29/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #28FD 4190850(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO

**Date/Time Received:** 1/12/2026 09:26

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.016*	1	1/7/2026 08:16	1/19/2026	1/20/2026

Analyst	Tests
JD	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 490341****1/29/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #28FL 4190886(SO#-54356-NORWES)  
**Source City:** Kansas City  
**Source State:** MO**Date/Time Received:** 1/12/2026 09:26**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/7/2026 08:18		1/20/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*