

# Report received by DSS on March 26, 2026

## NOTICE OF TEST RESULTS

Facility: Riverbend Treatment Center

Test Date: January 13, 2026

Date Results Received: March 4, 2026

### Summary of Results:

- Type of Result: Final
- Number of Outlets Tested: 43
- Number of Outlets with results at or above 5ppb: 6
  - See enclosed email from vendor

### Implemented Remediation Efforts:

- Install filtration system from Walter Louis Fluid Technologies and post non potable water sign above fixture.

### OA-FMDC Next Steps:

- All fixtures above 5PPB will be retested once remediation is complete

### Requirements of Statute:

- DYS must make all test results and any lead remediation plans available on the school's website within two weeks of receiving said test result. R.S.Mo. § 160.077.4(3)
- If a test result exceeds 5ppb, DYS shall contact parents and staff via written notification within seven business days of the above date. This notice must include:
  - The above written test results and explanation;
  - A description of the previously implemented and planned remediation efforts; and
  - A description of general health effects of lead contamination and community specific resources. *Id.* at (7).
- OA-FMDC shall provide bottled water if the disuse of outlets during the remediation and retesting period results in not enough water to meet the drinking water needs of the students, teachers, and staff. *Id.*
- DYS shall submit annual testing results to DHSS. *Id.*

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
<b>86</b>	<b>Riverbend Treatment Center - St. Joseph, MO</b>	5910 Mitchell Avenue St. Joseph, MO 64507	SO# 54354	
1	SAMPLE LOCATION	1 <b>FD</b> C-135 Water Main - Core Building	0.900 mg/L	900 ppb
2	SAMPLE LOCATION	1 <b>FL</b> C-135 Water Main - Core Building	0.048 mg/L	48 ppb
3	SAMPLE LOCATION	2 <b>FD</b> C-114 Staff Restroom Faucet	ND	ND
4	SAMPLE LOCATION	2 <b>FL</b> C-114 Staff Restroom Faucet	ND	ND
5	SAMPLE LOCATION	3 <b>FD</b> C-115 Corridor Drinking Fountain	ND	ND
6	SAMPLE LOCATION	3 <b>FL</b> C-115 Corridor Drinking Fountain	ND	ND
7	SAMPLE LOCATION	4 <b>FD</b> C-107 Staff Restroom Faucet	ND	ND
8	SAMPLE LOCATION	4 <b>FL</b> C-107 Staff Restroom Faucet	ND	ND
9	SAMPLE LOCATION	5 <b>FD</b> C-111 Nurse's Office Faucet	0.002 mg/L	2 ppb
10	SAMPLE LOCATION	5 <b>FL</b> C-111 Nurse's Office Faucet	ND	ND
11	SAMPLE LOCATION	6 <b>FD</b> C-106B Student Boys Restroom Faucet	0.003 mg/L	3 ppb
12	SAMPLE LOCATION	6 <b>FL</b> C-106B Student Boys Restroom Faucet	ND	ND
13	SAMPLE LOCATION	7 <b>FD</b> C-105 Drinking Fountain	ND	ND
14	SAMPLE LOCATION	7 <b>FL</b> C-105 Drinking Fountain	ND	ND
15	SAMPLE LOCATION	8 <b>FD</b> C-105 Drinking Fountain	ND	ND
16	SAMPLE LOCATION	8 <b>FL</b> C-105 Drinking Fountain	ND	ND
17	SAMPLE LOCATION	9 <b>FD</b> C-106A Student Boys Restroom Faucet	ND	ND
18	SAMPLE LOCATION	9 <b>FL</b> C-106A Student Boys Restroom Faucet	ND	ND
19	SAMPLE LOCATION	10 <b>FD</b> C-127 Drinking Fountain	ND	ND
20	SAMPLE LOCATION	10 <b>FL</b> C-127 Drinking Fountain	ND	ND
21	SAMPLE LOCATION	11 <b>FD</b> C-127 Drinking Fountain	ND	ND
22	SAMPLE LOCATION	11 <b>FL</b> C-127 Drinking Fountain	ND	ND

**FD = First Draw**      **FL = Flush**

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
<b>86</b>	<b>Riverbend Treatment Center - St. Joseph, MO</b>	5910 Mitchell Avenue St. Joseph, MO 64507	SO# 54354	
23	SAMPLE LOCATION	12 <b>FD</b> C-139 Staff Restroom Faucet Kitchen	ND	ND
24	SAMPLE LOCATION	12 <b>FL</b> C-139 Staff Restroom Faucet Kitchen	ND	ND
25	SAMPLE LOCATION	13 <b>FD</b> C-131 Ice Machine	ND	ND
26	SAMPLE LOCATION	13 <b>FL</b> C-131 Ice Machine	ND	ND
27	SAMPLE LOCATION	14 <b>FD</b> C-131 Kitchen Faucet 1	ND	ND
28	SAMPLE LOCATION	14 <b>FL</b> C-131 Kitchen Faucet 1	ND	ND
29	SAMPLE LOCATION	15 <b>FD</b> C-131 Kitchen Faucet 2	0.002 mg/L	2 ppb
30	SAMPLE LOCATION	15 <b>FL</b> C-131 Kitchen Faucet 2	ND	ND
31	SAMPLE LOCATION	16 <b>FD</b> C-131 Kitchen Handwashing Faucet	0.280 mg/L	280 ppb
32	SAMPLE LOCATION	16 <b>FL</b> C-131 Kitchen Handwashing Faucet	ND	ND
33	SAMPLE LOCATION	17 <b>FD</b> C-131 Kitchen Dish Machine	ND	ND
34	SAMPLE LOCATION	17 <b>FL</b> C-131 Kitchen Dish Machine	ND	ND
35	SAMPLE LOCATION	18 <b>FD</b> C-131 Kitchen Faucet Sprayer	ND	ND
36	SAMPLE LOCATION	18 <b>FL</b> C-131 Kitchen Faucet Sprayer	ND	ND
37	SAMPLE LOCATION	19 <b>FD</b> C-131 Kitchen Faucet	ND	ND
38	SAMPLE LOCATION	19 <b>FL</b> C-131 Kitchen Faucet	ND	ND
39	SAMPLE LOCATION	20 <b>FD</b> SD-209 Water Main - Building A	0.016 mg/L	16 ppb
40	SAMPLE LOCATION	20 <b>FL</b> SD-209 Water Main - Building A	ND	ND
41	SAMPLE LOCATION	21 <b>FD</b> SD211 Restroom Faucet	ND	ND
42	SAMPLE LOCATION	21 <b>FL</b> SD211 Restroom Faucet	ND	ND
43	SAMPLE LOCATION	22 <b>FD</b> SD211 Restroom Faucet	ND	ND
44	SAMPLE LOCATION	22 <b>FL</b> SD211 Restroom Faucet	ND	ND

**FD = First Draw**      **FL = Flush**

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
<b>86</b>	<b>Riverbend Treatment Center - St. Joseph, MO</b>	5910 Mitchell Avenue St. Joseph, MO 64507	SO# 54354	
45	SAMPLE LOCATION	23 <b>FD</b> SD211 Restroom Faucet	ND	ND
46	SAMPLE LOCATION	23 <b>FL</b> SD211 Restroom Faucet	ND	ND
47	SAMPLE LOCATION	24 <b>FD</b> SD211 Restroom Faucet	ND	ND
48	SAMPLE LOCATION	24 <b>FL</b> SD211 Restroom Faucet	ND	ND
49	SAMPLE LOCATION	25 <b>FD</b> SD200 Dayroom Drinking Fountain	ND	ND
50	SAMPLE LOCATION	25 <b>FL</b> SD200 Dayroom Drinking Fountain	ND	ND
51	SAMPLE LOCATION	26 <b>FD</b> SD208 Staff Restroom Faucet	0.002 mg/L	2 ppb
52	SAMPLE LOCATION	26 <b>FL</b> SD208 Staff Restroom Faucet	ND	ND
53	SAMPLE LOCATION	27 <b>FD</b> SD-209 Water Main - Building B	0.036 mg/L	36 ppb
54	SAMPLE LOCATION	27 <b>FL</b> SD-209 Water Main - Building B	0.001 mg/L	1 ppb
55	SAMPLE LOCATION	28 <b>FD</b> SD-211 Restroom Faucet	ND	ND
56	SAMPLE LOCATION	28 <b>FL</b> SD-211 Restroom Faucet	ND	ND
57	SAMPLE LOCATION	29 <b>FD</b> SD-211 Restroom Faucet	0.004 mg/L	4 ppb
58	SAMPLE LOCATION	29 <b>FL</b> SD-211 Restroom Faucet	ND	ND
59	SAMPLE LOCATION	30 <b>FD</b> SD-211 Restroom Faucet	0.001 mg/L	1 ppb
60	SAMPLE LOCATION	30 <b>FL</b> SD-211 Restroom Faucet	ND	ND
61	SAMPLE LOCATION	31 <b>FD</b> SD-211 Restroom Faucet	0.002 mg/L	2 ppb
62	SAMPLE LOCATION	31 <b>FL</b> SD-211 Restroom Faucet	ND	ND
63	SAMPLE LOCATION	32 <b>FD</b> SD-200 Day Room Drinking Fountain	ND	ND
64	SAMPLE LOCATION	32 <b>FL</b> SD-200 Day Room Drinking Fountain	ND	ND
65	SAMPLE LOCATION	33 <b>FD</b> SD-208 Staff Restroom Faucet	0.002 mg/L	2 ppb
66	SAMPLE LOCATION	33 <b>FL</b> SD-208 Staff Restroom Faucet	ND	ND

**FD = First Draw      FL = Flush**

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
<b>86</b>	<b>Riverbend Treatment Center - St. Joseph, MO</b>	5910 Mitchell Avenue St. Joseph, MO 64507	SO# 54354	
67	SAMPLE LOCATION	34 <b>FD</b> SD-206 Isolation Acorn Drinking Fountain	0.011 mg/L	11 ppb
68	SAMPLE LOCATION	34 <b>FL</b> SD-206 Isolation Acorn Drinking Fountain	ND	ND
69	SAMPLE LOCATION	35 <b>FD</b> Vocation Rehab Faucet	0.002 mg/L	2 ppb
70	SAMPLE LOCATION	35 <b>FL</b> Vocation Rehab Faucet	ND	ND
71	SAMPLE LOCATION	36 <b>FD</b> Vocation Rehab Water Main	ND	ND
72	SAMPLE LOCATION	36 <b>FL</b> Vocation Rehab Water Main	ND	ND
73	SAMPLE LOCATION	37 <b>FD</b> SD-209 Water Main - Building C	0.018 mg/L	18 ppb
74	SAMPLE LOCATION	37 <b>FL</b> SD-209 Water Main - Building C	ND	ND
75	SAMPLE LOCATION	38 <b>FD</b> SD-211 Restroom Faucet	ND	ND
76	SAMPLE LOCATION	38 <b>FL</b> SD-211 Restroom Faucet	ND	ND
77	SAMPLE LOCATION	39 <b>FD</b> SD-211 Restroom Faucet	ND	ND
78	SAMPLE LOCATION	39 <b>FL</b> SD-211 Restroom Faucet	ND	ND
79	SAMPLE LOCATION	40 <b>FD</b> SD-211 Restroom Faucet	ND	ND
80	SAMPLE LOCATION	40 <b>FL</b> SD-211 Restroom Faucet	ND	ND
81	SAMPLE LOCATION	41 <b>FD</b> SD-211 Restroom Faucet	ND	ND
82	SAMPLE LOCATION	41 <b>FL</b> SD-211 Restroom Faucet	ND	ND
83	SAMPLE LOCATION	42 <b>FD</b> SD-200 Day Room Drinking Fountain	ND	ND
84	SAMPLE LOCATION	42 <b>FL</b> SD-200 Day Room Drinking Fountain	ND	ND
85	SAMPLE LOCATION	43 <b>FD</b> SD-208 Staff Restroom Faucet	ND	ND
86	SAMPLE LOCATION	43 <b>FL</b> SD-208 Staff Restroom Faucet	ND	ND

**FD = First Draw**      **FL = Flush**

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490630

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #1FD 4190678(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.900*	1	1/13/2026 07:38	1/27/2026	1/31/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490631

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #1FL 4190635(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.048*	1	1/13/2026 07:40		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490632

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #2FD 4190703(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:46		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490633

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #2FL 4190645(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:48		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490634

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #3FD 4190701(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:49		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490635

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #3FL 4190641(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:51		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490636

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #4FD 4190691(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:53		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490637

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #4FL 4190653(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:55		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490638

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #5FD 4190680(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	1/13/2026 07:56		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490639

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #5FL 4190658(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:58		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490640

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #6FD 4190681(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.003	1	1/13/2026 08:00		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490641

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #6FL 4190633(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:02		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490642

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #7FD 4190689(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:04		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## ANALYTICAL REPORTS

SAMPLE CODE: 490643

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808

Source: #7FL 4190638(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:06		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490644

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #8FD 4190700(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:06		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490645

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #8FL 4190668(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:08		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490646

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #9FD 4190676(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:09		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490647

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #9FL 4190639(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:11		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490648

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #10FD 4190674(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:31		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490649

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #10FL 4190651(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:33		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490650

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #11FD 4190704(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:34		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490651

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #11FL 4190646(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:36		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490652

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #12FD 4190690(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:26		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490653

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #12FL 4190634(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:28		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490654

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #13FD 4190699(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:12		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490655

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #13FL 4190664(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:14	1/27/2026	1/31/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490656

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #14FD 4190702(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:01		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490657

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #14FL 4190657(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:03		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490658

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #15FD 4190717 (SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	1/13/2026 07:04		1/25/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490659

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #15FL 4190660(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:06		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490660

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #16FD 4190707(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.280*	1	1/13/2026 07:07		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490661

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #16FL 4190644(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:09		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490662

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #17FD 4190722(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:12	1/27/2026	1/31/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490663

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #17FL 4190649(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:14	1/27/2026	1/31/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490664

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #18FD 4190715(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:15	1/27/2026	1/31/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490665

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #18FL 4190642(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:17		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490666

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #19FD 4190710(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:19		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490667

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #19FL 4190643(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 07:21		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 490668  
 2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #20FD 4190711(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.016*	1	1/13/2026 06:55		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490669

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #20FL 4190663(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:57		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490670

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #21FD 4190682(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:42		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490671

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #21FL 4190654(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:44		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490672

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #22FD 4190712(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:39		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490673

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #22FL 4190656(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:41		1/25/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490674

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #23FD 4190706(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:37		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490675

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #23FL 4190655(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:39		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490676

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #24FD 4190721(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:34		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166

(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490677

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808

Source: #24FL 4190632(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:36		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490678

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #25FD 4190698(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:46		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490679

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #25FL 4190665(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:48		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490680

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #26FD 4190709(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	1/13/2026 06:49		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490681

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #26FL 4190661(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:51		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 490682

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #27FD 4190716(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.036*	1	1/13/2026 06:27		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490683

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #27FL 4190666(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	1/13/2026 06:29		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490684

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #28FD 4190714(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:10		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 490685

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #28FL 4190673(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:12		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490686

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #29FD 4190675(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.004	1	1/13/2026 06:08	1/27/2026	1/31/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490687

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #29FL 4190652(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:10		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## ANALYTICAL REPORTS

SAMPLE CODE: 490688

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #30FD 4190677(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	1/13/2026 06:05		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490689

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #30FL 4190662(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:07		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490690

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #31FD 4190720(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	1/13/2026 06:02		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490691

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #31FL 4190659(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:04		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## ANALYTICAL REPORTS

SAMPLE CODE: 490692

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #32FD 4190713(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:14		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490693

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #32FL 4190650(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:16		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490694

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #33FD 4190708(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	1/13/2026 06:17		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490695

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #33FL 4190640(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:19		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490696

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #34FD 4190718(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.011*	1	1/13/2026 06:21		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490697

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #34FL 4190647(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 06:23		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 490698

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #35FD 4190679(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.002	1	1/13/2026 08:40		1/28/2026

Analyst	Tests
JD	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490699

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #35FL 4190667(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:42		1/28/2026

Analyst	Tests
JD	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490614

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #36FD 4190705(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw


Sample required a large dilution due to matrix interference, this resulted in a raised reporting level.

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.500	ND	RN 1	1/13/2026 08:45	1/27/2026	1/31/2026

Qualifiers:

RN: Please see Report Notes for qualifier detail.

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 490615

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #36FL 4190669(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush  
 Sample required a large dilution due to matrix interference, this resulted in a raised reporting level.

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.015	ND	RN 1	1/13/2026 08:47	1/27/2026	1/31/2026

Qualifiers:

RN: Please see Report Notes for qualifier detail.

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490616

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #37FD 4190685(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.018*	1	1/13/2026 08:33		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490617

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #37FL 4190672(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:35		1/24/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490618

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #38FD 4190684(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:22		1/24/2026

Analyst	Tests
DMJ	200.8

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 490619

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #38FL 4190631(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:24		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490620

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #39FD 4190688(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:20		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166

(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490621

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #39FL 4190636(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:22		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490622

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #40FD 4190696(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:18		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490623

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #40FL 4190627(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:20		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 490624

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #41FD 4190683(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:16		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490625

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #41FL 4190670(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

## Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:18		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490626

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #42FD 4190693(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:25		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 490627

2/26/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #42FL 4190629(SO#-54354-RIVBEN)  
 Source City: St. Joseph  
 Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:27		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490628

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #43FD 4190697(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

## Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:29		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

## National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585

## ANALYTICAL REPORTS

SAMPLE CODE: 490629

2/26/2026

Customer: Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808Source: #43FL 4190637(SO#-54354-RIVBEN)  
Source City: St. Joseph  
Source State: MO

Date/Time Received: 1/21/2026 09:54

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

## Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	1/13/2026 08:31		1/24/2026

Analyst	Tests
DMJ	200.8



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.