

## NOTICE OF TEST RESULTS

Facility: Sierra Osage

Test Date: February 11, 2026

Date Results Received: March 18, 2026

### Summary of Results:

- Type of Result: FINAL
- Number of Outlets Tested: 18
- Number of Outlets with results at or above 5ppb: 1
  - See enclosed email from vendor

### Implemented Remediation Efforts:

- Established disuse of above listed outlets and posted signage.
  - Install filtration system from Walter Louis Fluid Technologies and post non potable water sign above fixture.

### OA-FMDC Next Steps:

- All fixtures above 5PPB will be retested once remediation is complete

### Requirements of Statute:

- DYS must make all test results and any lead remediation plans available on the school's website within two weeks of receiving said test result. R.S.Mo. § 160.077.4(3)
- If a test result exceeds 5ppb, DYS shall contact parents and staff via written notification within seven business days of the above date. This notice must include:
  - The above written test results and explanation;
  - A description of the previously implemented and planned remediation efforts; and
  - A description of general health effects of lead contamination and community specific resources. *Id.* at (7).
- OA-FMDC shall provide bottled water if the disuse of outlets during the remediation and retesting period results in not enough water to meet the drinking water needs of the students, teachers, and staff. *Id.*
- DYS shall submit annual testing results to DHSS. *Id.*

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
<b>36</b>	<b>Division of Youth Services Dept. of Social Services - Poplar Bluff, MO (Sierra-Osage)</b>	9200 Sierra Osage Circle Drive Poplar Bluff, MO 63901	SO# 54569	
1	SAMPLE LOCATION	1 <b>FD</b> Lobby Sink	ND	ND
2	SAMPLE LOCATION	1 <b>FL</b> Lobby Sink	ND	ND
3	SAMPLE LOCATION	2 <b>FD</b> Source	0.009 mg/L	9 ppb
4	SAMPLE LOCATION	2 <b>FL</b> Source	ND	ND
5	SAMPLE LOCATION	3 <b>FD</b> Lobby Restroom Faucet	ND	ND
6	SAMPLE LOCATION	3 <b>FL</b> Lobby Restroom Faucet	ND	ND
7	SAMPLE LOCATION	4 <b>FD</b> Osage Dorm Bottle Filler	ND	ND
8	SAMPLE LOCATION	4 <b>FL</b> Osage Dorm Bottle Filler	ND	ND
9	SAMPLE LOCATION	5 <b>FD</b> Osage Dorm Laundry Sink	ND	ND
10	SAMPLE LOCATION	5 <b>FL</b> Osage Dorm Laundry Sink	ND	ND
11	SAMPLE LOCATION	6 <b>FD</b> Osage Dorm Restroom Faucet	ND	ND
12	SAMPLE LOCATION	6 <b>FL</b> Osage Dorm Restroom Faucet	ND	ND
13	SAMPLE LOCATION	7 <b>FD</b> Osage Dorm Restroom Faucet	ND	ND
14	SAMPLE LOCATION	7 <b>FL</b> Osage Dorm Restroom Faucet	ND	ND
15	SAMPLE LOCATION	8 <b>FD</b> Osage Dorm Restroom Faucet	ND	ND
16	SAMPLE LOCATION	8 <b>FL</b> Osage Dorm Restroom Faucet	ND	ND
17	SAMPLE LOCATION	9 <b>FD</b> Sierra Dorm Restroom Faucet	ND	ND
18	SAMPLE LOCATION	9 <b>FL</b> Sierra Dorm Restroom Faucet	ND	ND
19	SAMPLE LOCATION	10 <b>FD</b> Sierra Dorm Restroom Faucet	ND	ND
20	SAMPLE LOCATION	10 <b>FL</b> Sierra Dorm Restroom Faucet	ND	ND
21	SAMPLE LOCATION	11 <b>FD</b> Sierra Dorm Restroom Faucet	0.001 mg/L	1 ppb
22	SAMPLE LOCATION	11 <b>FL</b> Sierra Dorm Restroom Faucet	ND	ND

**FD** = First Draw      **FL** = Flush

# SAMPLES	NAME OF FACILITY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
<b>36</b>	<b>Division of Youth Services Dept. of Social Services - Poplar Bluff, MO (Sierra-Osage)</b>	9200 Sierra Osage Circle Drive Poplar Bluff, MO 63901	SO# 54569	
23	SAMPLE LOCATION	12 <b>FD</b> Sierra Dorm Laundry	ND	ND
24	SAMPLE LOCATION	12 <b>FL</b> Sierra Dorm Laundry	ND	ND
25	SAMPLE LOCATION	13 <b>FD</b> Sierra Dorm Bottle Filler	ND	ND
26	SAMPLE LOCATION	13 <b>FL</b> Sierra Dorm Bottle Filler	ND	ND
27	SAMPLE LOCATION	14 <b>FD</b> Boys Bathroom Faucet	ND	ND
28	SAMPLE LOCATION	14 <b>FL</b> Boys Bathroom Faucet	ND	ND
29	SAMPLE LOCATION	15 <b>FD</b> Nurse's Office Faucet	0.001 mg/L	1 ppb
30	SAMPLE LOCATION	15 <b>FL</b> Nurse's Office Faucet	ND	ND
31	SAMPLE LOCATION	16 <b>FD</b> Corridor Bottle Filler	ND	ND
32	SAMPLE LOCATION	16 <b>FL</b> Corridor Bottle Filler	ND	ND
33	SAMPLE LOCATION	17 <b>FD</b> Teacher's Bathroom Faucet	ND	ND
34	SAMPLE LOCATION	17 <b>FL</b> Teacher's Bathroom Faucet	ND	ND
35	SAMPLE LOCATION	18 <b>FD</b> Girls Bathroom Faucet	0.001 mg/L	1 ppb
36	SAMPLE LOCATION	18 <b>FL</b> Girls Bathroom Faucet	ND	ND

**FD = First Draw**      **FL = Flush**

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491868****3/13/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #1FD 4194276(SO#54569-  
MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:37		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491869****3/13/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #1FL 4194243(SO#54569-  
MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:39		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491870**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #2FD 4194265(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.009	1	2/11/2026 07:50		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491871**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #2FL 4194249(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:52		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491872**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #3FD 4194277(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:33		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491873**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #3FL 4194253(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:35		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491874**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #4FD 4194268(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:28		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491875**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #4FL 4194259(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:30		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491876**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #5FD 4194272(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:24		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491877**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #5FL 4194256(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:26		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491878**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #6FD 4194274(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:16		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491879**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #6FL 4194258(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:18		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491880**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #7FD 4194275(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:19		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491881**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #7FL 4194251(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:21		3/4/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491882**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #8FD 4194280(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:20		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491883**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #8FL 4194240(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:22		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491884**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #9FD 4194267(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:59		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491885**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #9FL 4194250(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:01		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 491886****3/13/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #10FD 4194266(SO#54569-  
MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO**Date/Time Received:** 2/17/2026 09:35**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:01		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491887**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #10FL 4194236(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:03		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491888**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #11FD 4194263(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	2/11/2026 07:04		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491889**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #11FL 4194246(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:04		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491890**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #12FD 4194278(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:07		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491891**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #12FL 4194257(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:09		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491892**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #13FD 4194279(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:10		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491893**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #13FL 4194255(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 07:12		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491894**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #14FD 4194261(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:52		3/3/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491895**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #14FL 4194245(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:54		3/12/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491896**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #15FD 4194264(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	2/11/2026 06:41		3/12/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491897**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #15FL 4194248(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:43		3/12/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491898**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #16FD 4194269(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:44		3/12/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491899**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #16FL 4194239(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:46		3/12/2026

Analyst	Tests
DMJ	200.8



Christine MacMillan, Technical Director

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491900**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #17FD 4194260(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:48		2/23/2026

Analyst	Tests
JD	200.8



Megan Gregg, Quality System Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491901**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #17FL 4194254(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:50		2/23/2026

Analyst	Tests
JD	200.8



Megan Gregg, Quality System Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491902**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #18FD 4194262(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	2/11/2026 06:37		2/23/2026

Analyst	Tests
JD	200.8



Megan Gregg, Quality System Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 491903**

**3/13/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #18FL 4194252(SO#54569-  
 MODEPSOC)(POPLAR BLUFF)  
**Source City:** Poplar Bluff  
**Source State:** MO

**Date/Time Received:** 2/17/2026 09:35

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
<b>Inorganic Analytes - Metals</b>										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	2/11/2026 06:39		2/23/2026

Analyst	Tests
JD	200.8



Megan Gregg, Quality System Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*