

# Report received by DSS on February 9, 2026

## NOTICE OF TEST RESULTS

Facility: Waverly Regional Youth Center

Test Date: December 16, 2025

Date Results Received: February 4, 2026

### Summary of Results:

- Type of Result: Final
- Number of Outlets Tested: 38
- Number of Outlets with results at or above 5ppb: 4
  - Kitchenette Faucet
  - Handwash Faucet Rehab Area
  - Water Main

### Implemented Remediation Efforts:

- Established disuse of above listed outlets and posted signage.
  - Install filtration system from Walter Louis Fluid Technologies and post non potable water sign above fixture.

### OA-FMDC Next Steps:

- All fixtures above 5PPB will be retested once remediation is complete

### Requirements of Statute:

- DYS must make all test results and any lead remediation plans available on the school's website within two weeks of receiving said test result. R.S.Mo. § 160.077.4(3)
- If a test result exceeds 5ppb, DYS shall contact parents and staff via written notification within seven business days of the above date. This notice must include:
  - The above written test results and explanation;
  - A description of the previously implemented and planned remediation efforts; and
  - A description of general health effects of lead contamination and community specific resources. *Id.* at (7).
- OA-FMDC shall provide bottled water if the disuse of outlets during the remediation and retesting period results in not enough water to meet the drinking water needs of the students, teachers, and staff. *Id.*
- DYS shall submit annual testing results to DHSS. *Id.*

| # SAMPLES | NAME OF FACILITY                            | ADDRESS                                       | FEDERAL LEVEL DETECTED<br>(Standard = < 0.015 mg/L)<br>(ND = Not Detected) | STATE OF MO LEVEL DETECTED<br>(Standard = < 5 ppb)<br>(ND = Not Detected) |
|-----------|---|---|--|---|
| 76        | Waverly Regional Youth Center - Waverly, MO | 109 West Kelling Avenue<br>Waverly, MO 64096  | SO# 54351  |   |
| 1         | SAMPLE LOCATION                             | 1 FD - West Restroom Conf Room Faucet         | 0.003 mg/L   | 3 ppb   |
| 2         | SAMPLE LOCATION                             | 1 FL - West Restroom Conf Room Faucet         | ND   | ND  |
| 3         | SAMPLE LOCATION                             | 2 FD - East Restroom Conf Room Faucet         | 0.002 mg/L   | 2 ppb   |
| 4         | SAMPLE LOCATION                             | 2 FL - East Restroom Conf Room Faucet         | ND   | ND  |
| 5         | SAMPLE LOCATION                             | 3 FD - Water Fountain between Restrooms       | ND   | ND  |
| 6         | SAMPLE LOCATION                             | 3 FL - Water Fountain between Restrooms       | ND   | ND  |
| 7         | SAMPLE LOCATION                             | 4 FD - Restroom in Hallway Corridor Faucet    | ND   | ND  |
| 8         | SAMPLE LOCATION                             | 4 FL - Restroom in Hallway Corridor Faucet    | ND   | ND  |
| 9         | SAMPLE LOCATION                             | 5 FD - Water Fountain End of Hallway Corridor | 0.002 mg/L   | 2 ppb   |
| 10        | SAMPLE LOCATION                             | 5 FL - Water Fountain End of Hallway Corridor | 0.002 mg/L   | 2 ppb   |
| 11        | SAMPLE LOCATION                             | 6 FD - Nurse's Office Faucet                  | 0.001 mg/L   | 1 ppb   |
| 12        | SAMPLE LOCATION                             | 6 FL - Nurse's Office Faucet                  | ND   | ND  |
| 13        | SAMPLE LOCATION                             | 7 FD - Water Fountain by Day Room             | ND   | ND  |
| 14        | SAMPLE LOCATION                             | 7 FL - Water Fountain by Day Room             | ND   | ND  |
| 15        | SAMPLE LOCATION                             | 8 FD - Voyager Dorm Faucet                    | ND   | ND  |
| 16        | SAMPLE LOCATION                             | 8 FL - Voyager Dorm Faucet                    | ND   | ND  |
| 17        | SAMPLE LOCATION                             | 9 FD - Voyager Dorm Faucet                    | ND   | ND  |
| 18        | SAMPLE LOCATION                             | 9 FL - Voyager Dorm Faucet                    | ND   | ND  |
| 19        | SAMPLE LOCATION                             | 10 FD - Voyager Dorm Faucet                   | ND   | ND  |
| 20        | SAMPLE LOCATION                             | 10 FL - Voyager Dorm Faucet                   | ND   | ND  |
| 21        | SAMPLE LOCATION                             | 11 FD - Voyager Dorm Faucet                   | ND   | ND  |
| 22        | SAMPLE LOCATION                             | 11 FL - Voyager Dorm Faucet                   | ND   | ND  |
| 23        | SAMPLE LOCATION                             | 12 FD - Family Therapy Faucet                 | 0.002 mg/L   | 2 ppb   |
| 24        | SAMPLE LOCATION                             | 12 FL - Family Therapy Faucet                 | ND   | ND  |
| 25        | SAMPLE LOCATION                             | 13 FD Kitchenette Faucet                      | 0.014 mg/L   | 14 ppb  |
| 26        | SAMPLE LOCATION                             | 13 FL - Kitchenette Faucet                    | ND   | ND  |

**FD = First Draw**      **FL = Flush**

| #<br>SAMPLES | NAME OF<br>FACILITY                                | ADDRESS  | FEDERAL<br>LEVEL DETECTED<br>(Standard = < 0.015 mg/L)<br>(ND = Not Detected) | STATE OF MO<br>LEVEL DETECTED<br>(Standard = < 5 ppb)<br>(ND = Not Detected) |
|--------------|--|--|---|--|
| <b>76</b>    | <b>Waverly Regional Youth Center - Waverly, MO</b> | 109 West Kelling Avenue<br>Waverly, MO 64096                           | SO# 54351   |  |
| 27           | SAMPLE LOCATION                                    | 14 <b>FD</b> - Horizon Dorm Faucet                                     | ND  | ND   |
| 28           | SAMPLE LOCATION                                    | 14 <b>FL</b> - Horizon Dorm Faucet                                     | ND  | ND   |
| 29           | SAMPLE LOCATION                                    | 15 <b>FD</b> - Horizon Dorm Faucet                                     | ND  | ND   |
| 30           | SAMPLE LOCATION                                    | 15 <b>FL</b> - Horizon Dorm Faucet                                     | ND  | ND   |
| 31           | SAMPLE LOCATION                                    | 16 <b>FD</b> - Day Room Faucet   | ND  | ND   |
| 32           | SAMPLE LOCATION                                    | 16 <b>FL</b> - Day Room Faucet   | ND  | ND   |
| 33           | SAMPLE LOCATION                                    | 17 <b>FD</b> - Kitchen Faucet with Hand Sprayer                        | ND  | ND   |
| 34           | SAMPLE LOCATION                                    | 17 <b>FL</b> - Kitchen Faucet with Hand Sprayer                        | ND  | ND   |
| 35           | SAMPLE LOCATION                                    | 18 <b>FD</b> - Kitchen Dishwasher                                      | ND  | ND   |
| 36           | SAMPLE LOCATION                                    | 18 <b>FL</b> - Kitchen Dishwasher                                      | ND  | ND   |
| 37           | SAMPLE LOCATION                                    | 19 <b>FD</b> - Kitchen Hand Wash Faucet                                | 0.002 mg/L  | 2 ppb  |
| 38           | SAMPLE LOCATION                                    | 19 <b>FL</b> - Kitchen Hand Wash Faucet                                | ND  | ND   |
| 39           | SAMPLE LOCATION                                    | 20 <b>FD</b> - Kitchen Faucet  | 0.003 mg/L  | 3 ppb  |
| 40           | SAMPLE LOCATION                                    | 20 <b>FL</b> - Kitchen Faucet  | ND  | ND   |
| 41           | SAMPLE LOCATION                                    | 21 <b>FD</b> - Kitchen Faucet  | ND  | ND   |
| 42           | SAMPLE LOCATION                                    | 21 <b>FL</b> - Kitchen Faucet  | ND  | ND   |
| 43           | SAMPLE LOCATION                                    | 22 <b>FD</b> - Kitchen Prep Sink Faucet                                | ND  | ND   |
| 44           | SAMPLE LOCATION                                    | 22 <b>FL</b> - Kitchen Prep Sink Faucet                                | ND  | ND   |
| 45           | SAMPLE LOCATION                                    | 23 <b>FD</b> - Kitchen Ice Maker Faucet                                | ND  | ND   |
| 46           | SAMPLE LOCATION                                    | 23 <b>FL</b> - Kitchen Ice Maker Faucet                                | ND  | ND   |
| 47           | SAMPLE LOCATION                                    | 24 <b>FD</b> - Kitchen Water Dispenser with Ice<br>(DOES NOT MAKE ICE) | 0.004 mg/L  | 4 ppb  |
| 48           | SAMPLE LOCATION                                    | 24 <b>FL</b> - Kitchen Water Dispenser with Ice<br>(DOES NOT MAKE ICE) | ND  | ND   |
| 49           | SAMPLE LOCATION                                    | 25 <b>FD</b> - Discovery Dorm Faucet                                   | ND  | ND   |
| 50           | SAMPLE LOCATION                                    | 25 <b>FL</b> - Discovery Dorm Faucet                                   | ND  | ND   |

**FD = First Draw      FL = Flush**

| #<br>SAMPLES | NAME OF<br>FACILITY                         | ADDRESS   | FEDERAL<br>LEVEL DETECTED<br>(Standard = < 0.015 mg/L)<br>(ND = Not Detected) | STATE OF MO<br>LEVEL DETECTED<br>(Standard = < 5 ppb)<br>(ND = Not Detected) |
|--------------|---|---|---|--|
| 76           | Waverly Regional Youth Center - Waverly, MO | 109 West Kelling Avenue<br>Waverly, MO 64096          | SO# 54351   |  |
| 51           | SAMPLE LOCATION                             | 26 FD - Discovery Dorm Faucet                         | ND  | ND   |
| 52           | SAMPLE LOCATION                             | 26 FL - Discovery Dorm Faucet                         | ND  | ND   |
| 53           | SAMPLE LOCATION                             | 29 FD - Target Dorm Faucet                            | ND  | ND   |
| 54           | SAMPLE LOCATION                             | 29 FL - Target Dorm Faucet                            | ND  | ND   |
| 55           | SAMPLE LOCATION                             | 30 FD - Target Dorm Faucet                            | ND  | ND   |
| 56           | SAMPLE LOCATION                             | 30 FL - Target Dorm Faucet                            | ND  | ND   |
| 57           | SAMPLE LOCATION                             | 31 FD Handwash Faucet Rehab Area                      | 0.012 mg/L  | 12 ppb   |
| 58           | SAMPLE LOCATION                             | 31 FL - Handwash Faucet Rehab Area                    | ND  | ND   |
| 59           | SAMPLE LOCATION                             | 32 FD Water Main                                      | 0.017 mg/L  | 17 ppb   |
| 60           | SAMPLE LOCATION                             | 32 FL Water Main                                      | 0.024 mg/L  | 24 ppb   |
| 61           | SAMPLE LOCATION                             | 33 FD - Maintenance Area Restroom Faucet              | ND  | ND   |
| 62           | SAMPLE LOCATION                             | 33 FL - Maintenance Area Restroom Faucet              | ND  | ND   |
| 63           | SAMPLE LOCATION                             | 34 FD - Restroom Faucet                               | ND  | ND   |
| 64           | SAMPLE LOCATION                             | 34 FL - Restroom Faucet                               | ND  | ND   |
| 65           | SAMPLE LOCATION                             | 35 FD - Restroom Faucet                               | ND  | ND   |
| 66           | SAMPLE LOCATION                             | 35 FL - Restroom Faucet                               | ND  | ND   |
| 67           | SAMPLE LOCATION                             | 36 FD - Restroom Faucet                               | ND  | ND   |
| 68           | SAMPLE LOCATION                             | 36 FL - Restroom Faucet                               | ND  | ND   |
| 69           | SAMPLE LOCATION                             | 37 FD - Water Fountain Hi                             | ND  | ND   |
| 70           | SAMPLE LOCATION                             | 37 FL - Water Fountain Hi                             | ND  | ND   |
| 71           | SAMPLE LOCATION                             | 38 FD - Water Fountain Lo                             | ND  | ND   |
| 72           | SAMPLE LOCATION                             | 38 FL - Water Fountain Lo                             | ND  | ND   |
| 73           | SAMPLE LOCATION                             | 39 FD - Main Corridor Water Fountain Bottle Filler Hi | ND  | ND   |
| 74           | SAMPLE LOCATION                             | 39 FL - Main Corridor Water Fountain Bottle Filler Hi | ND  | ND   |
| 75           | SAMPLE LOCATION                             | 40 FD - Main Corridor Water Fountain Bubbler Lo       | ND  | ND   |
| 76           | SAMPLE LOCATION                             | 40 FL - Main Corridor Water Fountain Bubbler Lo       | ND  | ND   |

**FD = First Draw**      **FL = Flush**

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489699**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #1FD 4190349(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.003          | 1  | 12/16/2025 08:28  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489700**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #1FL 4190290(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:30  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489701**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #2FD 4190337(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.002          | 1  | 12/16/2025 08:31  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489702**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #2FL 4190295(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:33  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 489703****1/9/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #3FD 4190342(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO**Date/Time Received:** 12/22/2025 08:40**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:34  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489704**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #3FL 4190327(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:36  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489705**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #4FD 4190331(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:01  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489706**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #4FL 4190306(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:03  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489707**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #5FD 4190344(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.002          | 1  | 12/16/2025 08:05  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489708**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #5FL 4190303(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.002          | 1  | 12/16/2025 08:07  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489709**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #6FD 4190366(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.001          | 1  | 12/16/2025 07:55  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489710**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #6FL 4190291(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:57  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489711**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #7FD 4190364(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:09  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489712**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #7FL 4190307(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:11  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489713**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #8FD 4190363(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:00  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489714**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy , IL 62301-4808

**Source:** #8FL 4190312(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:02  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489715**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #9FD 4190367(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:03  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489716**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #9FL 4190309(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:05  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489717**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #10FD 4190372(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:06  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**556 South Mansfield, Ypsilanti, MI, 48197-5166  
(440) 449-2525, Fax: (440) 449-8585**ANALYTICAL REPORTS****SAMPLE CODE: 489718****1/9/2026****Customer:** Walter Louis Fluid Technologies  
Jenn Tapuaiga  
530 South 5th Street  
ATTN: Jenn Tapuaiga  
Quincy, IL 62301-4808**Source:** #10FL 4190310(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO**Date/Time Received:** 12/22/2025 08:40**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)**"NA"** Not Analyzed**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.**"DF"** This column indicates the contaminant dilution factor.**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:08  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489719**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #11FD 4190359(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:09  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489720**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy , IL 62301-4808

**Source:** #11FL 4190332(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:11  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489721**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #12FD 4190339(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.002          | 1  | 12/16/2025 07:52  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489722**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #12FL 4190302(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:54  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489723**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #13FD 4190343(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.014*         | 1  | 12/16/2025 07:48  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489724**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #13FL 4190318(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:50  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489725**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #14FD 4190356(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:40  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489726**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #14FL 4190308(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:42  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489727**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #15FD 4190341(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:43  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489728**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #15FL 4190287(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:45  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489729**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #16FD 4190354(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:27  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489730**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #16FL 4190319(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:29  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489731**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #17FD 4190345(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:21  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

**National Testing Laboratories, Ltd**

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

**ANALYTICAL REPORTS**

**SAMPLE CODE: 489732**

**1/9/2026**

**Customer:** Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

**Source:** #17FL 4190300(SO#-54351-WAVREG)  
**Source City:** Waverly  
**Source State:** MO

**Date/Time Received:** 12/22/2025 08:40

**Collected by:** N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

**Legend:**

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

**"ND"** This contaminant was not detected at or above our lower reporting limit (LRL)

**"NA"** Not Analyzed

**"Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

**"LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

**"DF"** This column indicates the contaminant dilution factor.

**Report Notes:**

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:23  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

*This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.*

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489733

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #18FD 4190351(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:15  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489734

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #18FL 4190324(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:17  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489735

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #19FD 4190348(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.002          | 1  | 12/16/2025 07:04  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489736

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #19FL 4190289(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:04  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489737

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #20FD 4190360(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.003          | 1  | 12/16/2025 06:56  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489738

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #20FL 4190297(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:58  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489739

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #21FD 4190332(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:59  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489740

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #21FL 4190325(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:01  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489741

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #22FD 4190333(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:01  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166

(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489742

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #22FL 4190292(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:03  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489743

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #23FD 4190357(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:09  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489744

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #23FL 4190320(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:11  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166

(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489745

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #24FD 4190353(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.004          | 1  | 12/16/2025 07:12  | 1/6/2026     | 1/6/2026           |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Christine MacMillan, Technical Director

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489746

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #24FL 4190296(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:14  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489747

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #25FD 4190371(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:24  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489748

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #25FL 4190316(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:26  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489749

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #26FD 4190369(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:26  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489750

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #26FL 4190294(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:28  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489751

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #29FD 4190368(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:14  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166

(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489752

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #29FL 4190304(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:16  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166

(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489753

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #30FD 4190355(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:17  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489754

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #30FL 4190323(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:19  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489755

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #31FD 4190334(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.012*         | 1  | 12/16/2025 08:21  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489756

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #31FL 4190315(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:23  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489757

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #32FD 4190362(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.017*         | 1  | 12/16/2025 08:16  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166

(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489758

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #32FL 4190286(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | 0.024*         | 1  | 12/16/2025 08:18  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489759

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #33FD 4190335(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:24  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489760

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #33FL 4190317(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 08:26  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166

(440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489761

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #34FD 4190346(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:36  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489762

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #34FL 4190328(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:38  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489763

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #35FD 4190365(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:40  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489764

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #35FL 4190326(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:42  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489765

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #36FD 4190370(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:42  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489766

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #36FL 4190311(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:44  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489767

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #37FD 4190361(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:47  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489768

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #37FL 4190288(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:49  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489769

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #38FD 4190350(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:49  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489770

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #38FL 4190293(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 06:51  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489771

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #39FD 4190347(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.


"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:33  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489772

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #39FL 4190284(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.


- "ND" This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA" Not Analyzed
- "Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                           | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|------------------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| <b>Inorganic Analytes - Metals</b> |             |        |          |       |       |                |    |                   |              |                    |
| 1030                               | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:35  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

National Testing Laboratories, Ltd

556 South Mansfield, Ypsilanti, MI, 48197-5166  
 (440) 449-2525, Fax: (440) 449-8585

ANALYTICAL REPORTS

SAMPLE CODE: 489773

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #40FD 4190340(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

First Draw

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:36  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |

Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 489774

1/9/2026

Customer: Walter Louis Fluid Technologies  
 Jenn Tapuaiga  
 530 South 5th Street  
 ATTN: Jenn Tapuaiga  
 Quincy, IL 62301-4808

Source: #40FL 4190321(SO#-54351-WAVREG)  
 Source City: Waverly  
 Source State: MO

Date/Time Received: 12/22/2025 08:40

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (\*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

"ND" This contaminant was not detected at or above our lower reporting limit (LRL)

"NA" Not Analyzed

"Standard" This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.

"LRL" This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.

"DF" This column indicates the contaminant dilution factor.

Report Notes:

Flush

| Fed Id #                    | Contaminant | Method | Standard | Units | LRL   | Level Detected | DF | Date/Time Sampled | Date Prepped | Date/Time Analyzed |
|-----------------------------|-------------|--------|----------|-------|-------|----------------|----|-------------------|--------------|--------------------|
| Inorganic Analytes - Metals |             |        |          |       |       |                |    |                   |              |                    |
| 1030                        | Lead        | 200.8  | 0.010    | mg/L  | 0.001 | ND             | 1  | 12/16/2025 07:38  |              | 12/31/2025         |

| Analyst | Tests |
|---------|-------|
| DMJ     | 200.8 |



Sarah Buchanan, Project Manager

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.