

NOTICE OF TEST RESULTS

Facility: W.E. Sears Youth Center (Oak and Pine Buildings)

Test Date: June 18, 2026

Date Results Received: July 14, 2026

Summary of Results:

- Type of Result: FINAL
- Number of Outlets Tested: 41
- Number of Outlets with results at or above 5ppb: 0
 - See enclosed email from vendor

Implemented Remediation Efforts:

- No remediations needed, facility passed test. Retesting in 5 years, per statute.

OA-FMDC Next Steps:

- No remediations needed, facility passed test. Retesting in 5 years, per statute.

Requirements of Statute:

- DYS must make all test results and any lead remediation plans available on the school's website within two weeks of receiving said test result. R.S.Mo. § 160.077.4(3)
- If a test result exceeds 5ppb, DYS shall contact parents and staff via written notification within seven business days of the above date. This notice must include:
 - The above written test results and explanation;
 - A description of the previously implemented and planned remediation efforts; and
 - A description of general health effects of lead contamination and community specific resources. *Id.* at (7).
- OA-FMDC shall provide bottled water if the disuse of outlets during the remediation and retesting period results in not enough water to meet the drinking water needs of the students, teachers, and staff. *Id.*
- DYS shall submit annual testing results to DHSS. *Id.*

# SAMPLES	NAME OF FACILTY	ADDRESS	FEDERAL LEVEL DETECTED (Standard = < 0.015 mg/L) (ND = Not Detected)	STATE OF MO LEVEL DETECTED (Standard = < 5 ppb) (ND = Not Detected)
2	W.E. Sears Youth Center - Poplar Bluff, MO	9400 Sears Lane Poplar Bluff, MO 63901	SO# 2600375	
1	SAMPLE LOCATION	26 FD Kitchen Faucet Sprayer	0.001 mg/L	1 ppb
2	SAMPLE LOCATION	26 FL Kitchen Faucet Sprayer	ND	ND

FD = First Draw **FL** = Flush

ANALYTICAL REPORTS

SAMPLE CODE: 497431

7/10/2026

Customer: Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy , IL 62301-4808

Source: #26FD 4196113(SO#2600375-WESEYC)
Source City: Poplar Bluff
Source State: MO

Date/Time Received: 6/23/2026 09:36

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND"** This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA"** Not Analyzed
- "Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF"** This column indicates the contaminant dilution factor.

Report Notes:

First Draw

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	0.001	1	6/18/2026 09:00		6/25/2026

Analyst	Tests
DMJ	200.8



Elliot Hughes

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.

ANALYTICAL REPORTS

SAMPLE CODE: 497432

7/10/2026

Customer: Walter Louis Fluid Technologies
Jenn Tapuaiga
530 South 5th Street
ATTN: Jenn Tapuaiga
Quincy , IL 62301-4808

Source: #26FL 4196128(SO#2600375-WESEYC)
Source City: Poplar Bluff
Source State: MO

Date/Time Received: 6/23/2026 09:36

Collected by: N. Kiser

The results herein conform to TNI and ISO/IEC 17025:2017 standards, where applicable. These results may be used for compliance purposes, as required, unless otherwise narrated in the body of the report. The uncertainty of the test results are available upon request. All Dates and Times are reported as U.S. Eastern Time.

Legend:

Any 'Level Detected' marked with an asterisk (*) indicates that the value has exceeded the EPA Maximum Contaminant Level (MCL) or one of the Standards of Quality.

- "ND"** This contaminant was not detected at or above our lower reporting limit (LRL)
- "NA"** Not Analyzed
- "Standard"** This column indicates either the Maximum Contaminant Level (MCL) for EPA Primary Standards or the guideline values for EPA Secondary Standards.
- "LRL"** This column indicates the Lower Reporting Limit, which is the lowest level that the laboratory can detect a contaminant.
- "DF"** This column indicates the contaminant dilution factor.

Report Notes:

Flush

Fed Id #	Contaminant	Method	Standard	Units	LRL	Level Detected	DF	Date/Time Sampled	Date Prepped	Date/Time Analyzed
Inorganic Analytes - Metals										
1030	Lead	200.8	0.010	mg/L	0.001	ND	1	6/18/2026 09:02		6/25/2026

Analyst	Tests
DMJ	200.8



Elliot Hughes

This report cannot be reproduced, except in full, without the written approval of National Testing Laboratories, Ltd.